

<b><i>Regulated at the Customer's Tap</i></b>	<b><i>Your Water Results</i></b>	<b><i>Results Range</i></b>	<b><i>Action Level</i></b>	<b><i>EPA Goal (MCLG or MRDLG)</i></b>	<b><i>Likely Source</i></b>
Lead	4 ppb	1 results above AL (24 tested)	15 ppb	0 ppb	Erosion of natural deposits, corrosion of plumbing systems
Copper	930 ppb	1 results above AL (24 tested)	1300 ppb	1300 ppb	Erosion of natural deposits, corrosion of plumbing systems